



UNIDADE DE GESTÃO DE PROJECTOS ESPECIAIS

CABO VERDE RENEWABLE ENERGY AND IMPROVED UTILITY PERFORMANCE PROJECT

Av. China, Edif. Tribunal Constitucional, 3º andar
CP: 145, Chã-d'Areia, Cidade da Praia, Cabo Verde
Telefones: (+238) 261 75 84 / 261 59 39
Fax: (+238) 261 59 39

www.governo.cv

CLARIFICATION Nº7

Project: Renewable Energy and Improved Utility Performance Project (REIUPP)

Contract title: ISD No: 009/REIUP/UGPE - Engineering Procurement, and Construction for

- **FOGO island - Solar PV plant (capacity: 1.3 MWp)**
- **SANTO ANTAO island - Solar PV plant (capacity: 1.2 MWp)**
- **SAO NICOLAU island Solar PV plant (capacity: 0.4 MWp)**
- **MAIO island Solar PV plant (capacity: 0.4 MWp)**

QUESTION 17: *Do we need to consider clarifications as the Addendums and mention the numbers in the application submission form?*

Answer 17: No.

QUESTION 18: *In the document, section 7, 1.4 and 1.5 it is mentioned as*

" 1.4 Commissioning and Trial Operation Requirements

The average Performance Ratio of each of the PV plants measured or calculated on annual basis shall be at least 85 %. This is a pre-qualifying requirement and Applicants shall ensure that the PR obtained on their design simulation report complies with this requirement.

Answer 18: **The Initial selection requirements are the information requested in table 1 and 2 of the ISD – Initial Selection Document.**

QUESTION 19: *1.5 Testing and Quality Assurance Requirement:*

The Applicant shall submit a Quality Assurance Plan (QAP). This need not be an ISO 9001 compliant plan, but such certification shall be deemed favorable. "

Do we need to submit simulation reports and QAP along with the initial application?

Answer 19: **The Initial selection requirements are the information requested in table 1 and 2 the ISD – Initial Selection Document.**



UNIDADE DE GESTÃO DE PROJECTOS ESPECIAIS

CABO VERDE RENEWABLE ENERGY AND IMPROVED UTILITY PERFORMANCE PROJECT

Av. China, Edif. Tribunal Constitucional, 3º andar
CP: 145, Chã-d'Areia, Cidade da Praia, Cabo Verde
Telefones: (+238) 261 75 84 / 261 59 39
Fax: (+238) 261 59 39

www.governo.cv

QUESTION 20: *If the space available in the given space of the forms are not enough can we attach separate sheet containing the same structure.*

Answer 20: Yes.

QUESTION Nº21: *Reference to above initial selection please share procedure for application to be submitted electronically.*

Answer 21: The procedure for application to be submitted electronically is indicated in the Initial Selection document on Section II – Initial Selection Data Sheet (ISDS) ITA 17.1 page 17

UGPE, March 31, 2023.