



## UNIDADE DE GESTÃO DE PROJECTOS ESPECIAIS

### CABO VERDE RENEWABLE ENERGY AND IMPROVED UTILITY PERFORMANCE PROJECT

Avenida Amílcar Cabral, Ex. Edifício do BCV, 4º Andar  
CP nº 145, Plateau, Cidade da Praia - República de Cabo Verde  
Telefones: (+238) 261 75 84 / 261 59 39  
Fax: (+238) 261 59 39

[www.governo.cv](http://www.governo.cv)

**Country: Cabo Verde**

**Name of Project: Renewable Energy and Improved Utility Performance Project**

**Contract Title: Supply, Installation and Commissioning of Grid-Connected Photovoltaic Systems for self-consumption of the Health Centers of Cabo Verde and Equipment for Energy Efficiency**

**Grant: Canada Clean Energy and Forest Climate Facility Grant No - TF-B6853**

**RFB Reference No.: 011/REIUP/UGPE**

#### NOTIFICATION Nº 5

**QUESTION Nº05: *Can we add Columns to the displayed BoQ –Annex file?***

**Answer Nº 05:** Yes. However, the based contente and structure of the BoQ shall not be changed.

**QUESTION Nº 06: *Would we like to receive the annual energy consumption data of each installation site, so that we can do simulation of Self-consumption?***

**Answer Nº 06:** Information not available

**QUESTION Nº 07: *If possible provide us with an image of each place where you want to install the Panels, to make 3D layout, of installations of the Panels***

**Answer Nº 07:** Please refer to RFB, Section VII- Schedule of Requirement- 3.1.2 Identification of sites and locations.

**QUESTION Nº 08: *BoQ-Annex-1\_UGPE / FORM 4.1 Solar PV System BoQ:***

***Item***

***PV array mounting super-structure***

***Please be so kind and define what is understood by the third separate part of this item, Module mounting security frames“ in detail.***

**Answer Nº 08:** This is a Safety structures for mounting modules. This is part of the PV array mounting structure.



## UNIDADE DE GESTÃO DE PROJECTOS ESPECIAIS

### CABO VERDE RENEWABLE ENERGY AND IMPROVED UTILITY PERFORMANCE PROJECT

Avenida Amílcar Cabral, Ex. Edifício do BCV, 4º Andar  
CP nº 145, Plateau, Cidade da Praia - República de Cabo Verde  
Telefones: (+238) 261 75 84 / 261 59 39  
Fax: (+238) 261 59 39

[www.governo.cv](http://www.governo.cv)

**QUESTION Nº 09:** *Is there any kind of exemption from customs duties for this project?*

**Answer Nº 09:** All goods, works and services for the Project, CABO VERDE RENEWABLE ENERGY AND IMPROVED UTILITY PERFORMANCE PROJECT are exempted of VAT payment. The Project is exempted from payment of VAT, in the Client's country as per the Decree-Law 88/2005 of December 26, 2005.

**QUESTION Nº 10:** *If additional positions in the BoQ are needed, can we insert them as additional rows at the appropriate position or shall we put them under the position "Others"?*

**Answer Nº 10:** Yes. They must be inserted at the appropriate position.

**QUESTION Nº 11:** *Since we want to quote in EUR can we modify each excel cell of the BoQ filled with „USD“ replacing it with „EUR“ and “CVE”?*

**Answer Nº 11:** Please refer to ITB 15.1.

**QUESTION Nº 12:** *How is the 10% penalty in case of delay charged? Is there always the full quoted price in consideration or is it charged per site that is delayed?*

**Answer Nº 12:** Please refer to GCC 27.1

### **QUESTION Nº 13: 3.3.2. INVERTERS**

#### **Technical Requirements**

**Inverters must comply with the following requirements:**

**Have total harmonic distortion (THD) lower than 2%;**

➔ **The value met by almost all brands is lower than 3%**

**Have the ability to operate at power factor between 0 and 1, inductive and capacitive**

➔ **The standard by almost all brands is lower than 0,8-1, inductive and capacitive**

**By requesting these values, you are cutting out almost all leading Inverter brands. Is there a particular reason for that? Does the Cape Verde Grid Code or Utility requests higher standards than the EU?**



Ministério das Finanças  
e do Fomento Empresarial  
Unidade de Gestão  
de Projetos Especiais

## UNIDADE DE GESTÃO DE PROJECTOS ESPECIAIS

---

### CABO VERDE RENEWABLE ENERGY AND IMPROVED UTILITY PERFORMANCE PROJECT

Avenida Amílcar Cabral, Ex. Edifício do BCV, 4º Andar  
CP nº 145, Plateau, Cidade da Praia - República de Cabo Verde  
Telefones: (+238) 261 75 84 / 261 59 39  
Fax: (+238) 261 59 39

[www.governo.cv](http://www.governo.cv)

**Answer Nº 13:** Please refer to the AMENDMENT #3 - RFB Refº: 011/REIUP/UGPE

UGPE, August 02, 2023