



Ministério das Finanças
e do Fomento Empresarial

Unidade de Gestão
de Projetos Especiais

UNIDADE DE GESTÃO DE PROJECTOS ESPECIAIS

CABO VERDE RENEWABLE ENERGY AND IMPROVED UTILITY PERFORMANCE PROJECT

Av. Amílcar Cabral, Ex Edifício do BCV, 4º andar
PO Box 145, Plateau, Cidade da Praia, Cabo Verde
Telefones: (+238) 261 75 84 / 261 59 39
Fax: (+238) 261 59 39

www.governo.cv

CLARIFICATION # 10

Country: Cabo Verde

Name of Project: Renewable Energy and Improved Utility Performance Project

Contract Title: Request for Bidding - Procurement of Plant, Design, Supply, and Installation for Five (5) Energy Storage Systems in FOGO Island, SANTO ANTÃO Island, SÃO NICOLAU Island, MAIO Island and BRAVA Island Cabo Verde

Loan No IBRD-92980

RFB Reference No.: 016/REIUP/UGPE_2

QUESTION 59: *In the APPENDIX3-POWERCONVERSION SYSTEM PCS) document, 2.1 GENERAL The PCS shall consist of multiple identical units, with the following overall guaranteed ratings as a minimum.*

Is that means all the PCS for five stations should use same specification type units? or only the PCS specification should be the same type in each stations, then five stations could have five type of PCS which qualified for overall guaranteed ratings is accept.

ANSWER N° 59: Please refer to appendix 3 #2. The bidder shall design the PCS as specified in the Employer's Requirements.

For a maintenance purpose, the Employer recommends to offer the same type of PCS (power must be optimized site by site).

May 16, 2024